

**Addendum No.3 dated 11/04/15 to Spears® FlameGuard® Installation Manual (FG-3) dated 10/04/10
Combustible Concealed Installations with Specific Use Sprinklers**

FG-3ADD3-1115

In accordance with UL Listing, Spears® FlameGuard® CPVC Fire Sprinkler Products can be used in specific light-hazard, combustible concealed and noncombustible concealed spaces that require sprinkler protection when installed with UL Listed Victaulic Model V2502; UL Listed Tyco Fire Products Model CC1 – 2.8 K-Factor, Model CC2 – 4.2 K or 5.6 K-Factor Combustible Concealed Space Sprinklers, Specific Application Upright; or UL Listed Viking Microfast® COIN™ Quick Response Combustible Interstitial Space Upright Sprinklers for Specific Application; or UL Listed Reliable Model KFR-CSS 56 Combustible Concealed Space Upright Sprinkler.

The system must be installed in accordance with the applicable sprinkler manufacturer's information contained in Victaulic Model V2502, Submittal 40.09 Rev D; Tyco Fire Products Model CC1 – 2.8 K-Factor Combustible Concealed Space Sprinkler Technical Data Sheet (dated July 2015), Tyco Fire Products Model CC2 – 4.2 K or 5.6 K-Factor Combustible Concealed Space Sprinkler Technical Data Sheet (dated July 2015) ; Viking Microfast® COIN™ Quick Response Upright Sprinkler SIN VK900 (Specific Application) Technical Data Sheet (dated January 2011); or Reliable Automatic Sprinkler Co. Combustible Concealed Space Upright Sprinkler Bulletin 044 Rev. B.

NOTICE: When installing Spears® FlameGuard® CPVC Fire Sprinkler Products in combustible concealed areas where sprinklers are required, the specific application sprinkler must be used in accordance with the UL Listing. Contact the local authority having jurisdiction with questions concerning code requirements.